

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 44

Dated: 24.4.2026

It is certified that an inspection team headed by Bhalla Ram Saran (Sarpanch)
 (Name of Officers with designation) from Pal Panchayat
 (Name of Department/ Office) inspected the Our Lady of Pillar Convent School Jodhpur
 (Name & Address of the school) on 24/04/2026 (date of inspection) and found that the
Our Lady of Pillar Convent School (Name of school) has safe drinking water
 facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the Central/
 State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal: (भल्लाराम सारण)
प्रशासक
ग्राम पंचायत पाल
पं.स. लूणी जोधपुर (राज.)

Name : Bhalla Ram Saran
 Designation : Sarpanch (प्रशासक पदा)
 Name & Address of the Office / Department : Pal Panchayat

To

Our Lady of Pillar Convent School
Gangana Road, Pal Village, Jodhpur 342014 (Raj.)
 (Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Principal
 Our Lady of Pillar Convent School
 GANGANA ROAD, PAL VILLAGE
 JODHPUR-342001 (RAJ.)

Sr. Yovanna
 Manager
 Our Lady of Pillar Convent School
 GANGANA ROAD, PAL VILLAGE
 JODHPUR-342001 (RAJ.)



**OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT,
REGIONAL LABORATORY-JODHPUR (RAJ.)**

Email:- phedregionallabjodhpur@gmail.com

No. Lab/Tech/Chm./2025-2026/ 214

Date : 18-07-2025

TEST REPORT OF THE CHEMICAL EXAMINATION OF WATER

To,
PRINCIPAL
OUR LADY OF PILLAR CONVENT SCHOOL
GANGANA ROAD, PAL VILLAGE

SAMPLE WAS NOT COLLECTED
BY THE LABORATORY

Not for Legal Purpose

JODHPUR

District: JODHPUR

Reference: -

Dated: 11-07-2025

Sample Taker: NM

Date of Receipt	16-07-2025
Date of Collection	16-07-2025
Date of Examination	17.07.2025
Source Type	Tap Water
Source Location	OLOPCS, GANGANA ROAD, PAL VILLAGE
City	JODHPUR
Lab Sample No.	PC-36

S. No.	Characteristics	Permissible Value as per BIS 10500/2012 Drinking Water Standards		Test Results
		Desirable Limit	Permissible Limit in absence of alternate Source	
1	pH @ 25 °C	6.5 to 8.5	No relaxation	7.60
2	Turbidity(NTU)	1	5	0.20
3	Colour	5	15	0.20
4	Odour	Agreeable	Agreeable	Agreeable
5	Temperature	----	----	-
6	Total Alkalinity (as CaCO ₃)	200	600	92
7	Total Hardness (as CaCO ₃)	200	600	104
8	Calcium (as Ca ⁺⁺)	75	200	27.20
9	Magnesium (as Mg ⁺⁺)	30	100	8.64
10	Chloride (as Cl ⁻)	250	1000	36
11	Sulphate(as SO ₄)	200	400	14
12	Nitrates (as NO ₃ ⁻)	45	No relaxation	2.80
13	Fluoride (as F ⁻)	1	1.5	0.10
14	Total Dissolved Solids (TDS)	500	2000	190

Remark:-

Blank
Principal
Our Lady of Pillar Convent School
GANGANA ROAD, PAL VILLAGE
JODHPUR-342001 (RAJ.)

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur

No. Lab/Tech/Chm./2025-2026/

Date :

Copy to:

1. The Chief Chemist, Public Health Engineering Department-Rajasthan, Jaipur.

S. Jaiswal
Manager
Our Lady of Pillar Convent School
GANGANA ROAD, PAL VILLAGE
JODHPUR-342001 (RAJ.)

Superintending Chemist
P.H.E.D. Regional Lab., Jodhpur